

Psychrometric Table

For use at elevations between 6,101 and 8,500 feet

Wet Bulb Temperatures



	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85
81	-23	-5	5	12	17	22	26	30	33	36	39	42	44	46	48	50	52	54	56	58	60	61	63	64	66	68	69	70	72	73	75	76	77	78	80	81				
82	-40	-11	1	9	15	20	25	29	32	35	38	41	43	46	48	50	52	54	56	57	59	61	62	64	66	67	69	70	71	73	74	76	77	78	79	81				
83	-19	-3	6	13	19	23	27	31	34	37	40	42	45	47	49	51	53	55	57	59	60	62	64	65	67	68	70	71	73	74	75	77	78	79	80	82	83			
84	-31	-8	3	11	17	22	26	30	33	36	39	42	44	46	48	50	52	54	56	58	60	62	63	65	66	68	69	71	72	74	75	76	78	79	80	82	83	84		
85	-15	-1	8	14	20	24	28	32	35	38	41	43	46	48	50	52	54	56	58	59	61	63	64	66	68	69	70	72	73	75	76	77	79	80	81	83	84	85		
86	-25	-6	5	12	18	23	27	31	34	37	40	42	45	47	49	51	53	55	57	59	61	62	64	66	67	69	70	72	73	74	76	77	78	80	81	82	84	85		
87	-44	-12	1	9	16	21	26	29	33	36	39	42	44	46	49	51	53	55	57	59	60	62	64	65	67	68	70	71	73	74	75	77	78	79	81	82	83	85		
88	-20	-3	7	14	19	24	28	32	35	38	41	43	46	48	50	52	54	56	58	60	62	63	65	66	68	69	71	72	74	75	77	78	79	81	82	83	84			
89	-33	-8	3	11	17	22	27	30	34	37	40	43	45	47	50	52	54	56	58	59	61	63	64	66	68	69	71	72	73	75	76	78	79	80	82	83	84			
90	-15	-1	8	15	21	25	29	33	36	39	42	44	47	49	51	53	55	57	59	61	62	64	66	67	69	70	72	73	75	76	77	79	80	81	83	84	85			
91	-5	5	13	19	24	28	32	35	38	41	43	46	48	50	52	54	56	58	60	62	64	65	67	68	70	71	73	74	76	77	78	80	81	82	84					
92	-11	2	10	17	22	27	30	34	37	40	43	45	48	50	52	54	56	58	60	61	63	65	66	68	70	71	73	74	75	77	78	79	81	82	83					
93	-18	-2	8	15	20	25	29	33	36	39	42	44	47	49	51	53	55	57	59	61	63	64	66	68	69	71	72	74	75	76	78	79	81	82	83					
94	-31	-7	4	12	18	23	28	32	35	38	41	44	46	49	51	53	55	57	59	61	62	64	66	67	69	70	72	73	75	76	78	79	80	82	83					
95	-1	2	3	5	6	8	9	11	13	14	16	18	20	21	23	25	27	29	31	33	35	37	40	42	44	47	49	51	54	57	59	62	65	68	71					
96	-13	1	10	16	22	26	30	34	37	40	43	45	48	50	52	54	56	58	60	62	64	65	67	69	70	72	73	75	76	77	79	80	81	83						
97	-22	-3	7	14	20	25	29	33	36	39	42	45	47	50	52	54	56	58	60	61	63	65	67	68	70	71	73	74	76	77	78	80	81	82						
98	-38	-9	4	12	19	23	28	32	35	38	41	44	46	49	51	53	55	57	59	61	63	64	66	68	69	71	72	74	75	77	78	80	81	82						
99	-16	0	9	16	22	26	30	34	37	40	43	46	48	50	52	54	56	58	60	62	64	66	67	69	71	72	74	75	76	78	79	81	82							
100	-26	-5	6	14	20	25	29	33	36	39	42	45	48	50	52	54	56	58	60	62	64	65	67	69	70	72	73	75	76	78	79	80	82							
101	-47	-10	3	11	18	23	28	32	35	39	42	44	47	49	51	53	55	57	59	61	63	65	67	68	70	71	73	74	76	77	79	80	81							
102	-18	-1	9	16	22	26	30	34	37	40	43	46	48	50	52	54	56	58	60	61	63	65	66	68	70	71	73	74	76	77	78	80	81							
103	-29	-6	6	14	20	24	28	32	35	38	41	44	46	49	51	53	55	57	59	61	62	64	66	68	69	71	72	74	75	77	78	80	81							
104	-12	2	11	18	23	28	32	36	39	42	45	47	50	52	54	56	58	60	62	64	66	67	69	70	72	74	75	76	78	79	81									
105	-20	-2	9	16	22	27	31	35	38	41	44	46	49	51	53	55	57	59	61	62	63	65	66	68	70	72	73	75	76	78	79	80								
106	-33	-6	6	14	20	25	30	33	37	40	43	46	48	51	53	55	57	59	61	63	65	66	68	70	71	73	74	76	77	79	80									
107	1	3	4	5	6	7	9	10	11	12	14	15	17	18	20	21	23	25	27	29	31	33	34	36	38	40	42	44	46											

Dry Bulb Temperatures

